




7001 Dublin Park Dr
Dublin, Ohio 43016

PROJECT NUMBER: CHILL 10

ACOCK
ASSOCIATES
ARCHITECTS

383 North Front Street
Columbus, Ohio 43215
Ph: (614) 228-1586 Fax: (614) 228-2781



M-Engineering
100 Brooksedge Blvd.
Menterville, Ohio 43081
Phone: 614.839.4639
Fax: 614.839.2222
mengineering.us.com

 $1/8 \equiv 1 \cdot 0$

< > CODED NOTES M-1A

- 31 REBALANCE EXISTING SUPPLY AIR DEVICE TO CFM SHOWN.
- 32 PROVIDE NEW EXHAUST GRILLE IN EXISTING EXHAUST DUCT.
- 33 MAKE CONNECTION TO EXISTING SUPPLY AIR DUCT AND EXTEND AS SHOWN
TO NEW AIR DEVICE.
- 34 REBALANCE EXISTING EXHAUST AIR DEVICE TO CFM SHOWN.
- 35 PROVIDE A WALL MOUNTED AIR CURTAIN WITH ELECTRIC HEAT AS
SCHEDULED. MOUNT UNIT ABOVE ENTRY DOOR. PROVIDE MOUNTING
BRACKETS AS REQUIRED FOR INSTALLATION PER MANUFACTURERS
INSTALLATION INSTRUCTIONS.
- 36 PROVIDE NEW SUPPLY AIR DEVICE IN EXISTING SUPPLY AIR DUCT.

BUILDING DEPARTMENT COMMENT NOTES:

SCREEN ALL SERVICE STRUCTURES AND MECHANICAL UNITS PER DUBLIN CITY CODE.

SCALE: 1/8"=1'-0"

ISSUE DATE:

REVISIONS

NUMBER	DATE	NUMBER	DATE
1	02/27/2020		
2	04/17/2020		
3	05/14/2020		
5	06/19/2020		

M1A