

GENERAL NOTE:
A REFER TO SHEET FP3 FOR GENERAL NOTES, LEGEND, SCHEDULES AND SCHEMATICS.

- CODED NOTES:
- EXISTING FIRE PROTECTION PIPING AND HEADS IN THIS AREA TO REMAIN.
 - SPRINKLERS SPACED IN ACCORDANCE WITH LIGHT HAZARD DESIGN CRITERIA.
 - PROVIDE A NEW DRY SIDEWALL SPRINKLER HEAD FOR COVERAGE IN NEW VESTIBULE. MAKE CONNECTION TO EXISTING OVERHEAD SPRINKLER BRANCH AND EXTEND BRANCH LINE TO VESTIBULE. COORDINATE PIPE ROUTING WITH NEW VESTIBULE FRAMING.
 - EXISTING FIRE PROTECTION PIPING AND HEADS IN THIS AREA TO REMAIN. PROVIDE NEW ESCUTCHEONS ON HEADS.
 - MAKE CONNECTION TO EXISTING SPRINKLER LINE AND EXTEND TO NEW STORAGE ROOM CEILING AND PROVIDE SPRINKLER HEAD.
 - PROVIDE NEW SPRINKLER HEADS FOR COVERAGE BELOW THE NEW LOW-E CEILING OUTSIDE THE PERIMETER OF THE ICE RINK DASHER BOARDS AND BELOW THE NEW CEILING. MAKE CONNECTION TO EXISTING FIRE PROTECTION BRANCH LINES AND EXTEND AS REQUIRED FOR NEW SPRINKLER HEADS.
 - VERIFY MINIMUM MAXIMUM DISTANCE OF EXISTING SPRINKLER HEADS FROM NEW WALL AND PROVIDE NEW HEADS AS REQUIRED FOR COVERAGE.

FIRST FLOOR FIRE PROTECTION PLAN AREA A
1/8"=1'-0"

NEW SHEET ISSUED AS PART OF REVISION 2.

THIS CONTRACTOR SHALL PROVIDE 1/8" SCALE CAD COORDINATION DRAWINGS WITH ALL CONSTRUCTION TRADES. THE HVAC CONTRACTOR SHALL PROVIDE THE CAD COORDINATION DRAWING TO ALL OTHER TRADES. ALL OTHER TRADES SHALL SHOW THEIR WORK ON THE PROVIDED DRAWINGS. ONCE ALL WORK IS SHOWN, THE CONTRACTING TEAM SHALL MEET AS REQUIRED TO RESOLVE ALL COORDINATION CONFLICTS. NO WORK SHALL BE INSTALLED UNTIL THE COORDINATION DRAWINGS ARE RESOLVED AND SUBMITTED AND APPROVED BY THE DESIGN TEAM. THE CONTRACTING TEAM SHALL BE RESPONSIBLE FOR ALL TRADE CONFLICTS.



Dublin Chiller

7001 Dublin Park Dr.
Dublin, Ohio 43016


PROJECT NUMBER: CHILL 10

**ACOCK
ASSOCIATES
ARCHITECTS**

383 North Front Street
Columbus, Ohio 43215
Ph: (614) 228-1586 Fax: (614) 228-2780



M-Engineering
750 Brooksedge Blvd.
Westerville, Ohio 43081
phone: 614.839.4639
fax: 614.839.2222
www.mengineering.us.com



**FIRST FLOOR
FIRE PROTECTION
PLAN AREA A**

SCALE: 1/8"=1'-0"

ISSUE DATE:

REVISIONS

NUMBER	DATE	NUMBER	DATE
1	04/17/2020		
2	05/14/2020		
3	06/15/2020		

FP1A